



CERTIFICATE OF ANALYSIS

REPORTED TO	Interior Health Authority - Penticton 3090 Skaha Lake Rd Penticton, BC V2A 7H2		
ATTENTION	Ivor Norlin	WORK ORDER	26A1465
PO NUMBER		RECEIVED / TEMP	2026-01-16 09:50 / 6.3°C
PROJECT	Comprehensive 2026 for Ivor Norlin		REPORTED 2026-01-21 14:16
PROJECT INFO			COC NUMBER No Number

Introduction:

CARO Analytical Services is a testing laboratory full of smart, engaged scientists driven to make the world a safer and healthier place. Through our clients' projects we become an essential element for a better world. We employ methods conducted in accordance with recognized professional standards using accepted testing methodologies and quality control efforts. CARO is accredited by the Canadian Association for Laboratories Accreditation (CALA) to ISO/IEC 17025:2017 for specific tests listed in the scope of accreditation approved by CALA.

Big Picture Sidekicks



We've Got Chemistry



Ahead of the Curve



You know that the sample you collected after snowshoeing to site, digging 5 meters, and racing to get it on a plane so you can submit it to the lab for time sensitive results needed to make important and expensive decisions (whew) is VERY important. We know that too.

It's simple. We figure the more you enjoy working with our fun and engaged team members; the more likely you are to give us continued opportunities to support you.

Through research, regulation knowledge, and instrumentation, we are your analytical centre for the technical knowledge you need, BEFORE you need it, so you can stay up to date and in the know.

By engaging our services, you are agreeing to CARO Analytical Service's Standard Terms and Conditions outlined here:
<https://www.caro.ca/terms-conditions>

If you have any questions or concerns, please contact me at bwhitehead@caro.ca

Authorized By:

Brent Whitehead
Account Manager



1-888-311-8846 | www.caro.ca

#110 4011 Viking Way Richmond, BC V6V 2K9 | #102 3677 Highway 97N Kelowna, BC V1X 5C3 | 17225 109 Avenue Edmonton, AB T5S 1H7 | #108 4475 Wayburne Drive Burnaby, BC V5G 4X4




TEST RESULTS

REPORTED TO Interior Health Authority - Penticton
PROJECT Comprehensive 2026 for Ivor Norlin

WORK ORDER 26A1465
REPORTED 2026-01-21 14:16

Analyte	Result	Guideline	RL	Units	Analyzed	Qualifier
0210717; (26A1465-01) Matrix: Water Sampled: 2026-01-14						
Anions						
Chloride	0.66	AO ≤ 250	0.10	mg/L	2026-01-16	
Fluoride	< 0.10	MAC = 1.5	0.10	mg/L	2026-01-16	
Nitrate (as N)	0.355	MAC = 10	0.010	mg/L	2026-01-16	
Nitrite (as N)	< 0.010	MAC = 1	0.010	mg/L	2026-01-16	
Sulfate	15.3	AO ≤ 500	1.0	mg/L	2026-01-16	
Calculated Parameters						
Hardness, Total (as CaCO ₃)	97.2	None Required	0.500	mg/L	N/A	
Langelier Index	-0.3	N/A	-5.0		2026-01-21	CT6
Solids, Total Dissolved	115	AO ≤ 500	1.00	mg/L	N/A	
General Parameters						
Alkalinity, Total (as CaCO ₃)	94.1	N/A	1.0	mg/L	2026-01-20	
Alkalinity, Phenolphthalein (as CaCO ₃)	< 1.0	N/A	1.0	mg/L	2026-01-20	
Alkalinity, Bicarbonate (as CaCO ₃)	94.1	N/A	1.0	mg/L	2026-01-20	
Alkalinity, Carbonate (as CaCO ₃)	< 1.0	N/A	1.0	mg/L	2026-01-20	
Alkalinity, Hydroxide (as CaCO ₃)	< 1.0	N/A	1.0	mg/L	2026-01-20	
Colour, True	< 5.0	AO ≤ 15	5.0	CU	2026-01-16	
Conductivity (EC)	196	N/A	2.0	µS/cm	2026-01-21	
Cyanide, Total	< 0.0020	MAC = 0.2	0.0020	mg/L	2026-01-16	
pH	7.80	7.0-10.5	0.10	pH units	2026-01-20	HT2
Temperature, at pH	21.0	N/A	°C		2026-01-20	HT2
Turbidity	0.15	OG < 1	0.10	NTU	2026-01-16	
Total Metals						
Aluminum, total	< 0.0050	OG < 0.1	0.0050	mg/L	2026-01-19	
Antimony, total	< 0.00020	MAC = 0.006	0.00020	mg/L	2026-01-19	
Arsenic, total	< 0.00050	MAC = 0.01	0.00050	mg/L	2026-01-19	
Barium, total	0.0195	MAC = 2	0.0050	mg/L	2026-01-19	
Boron, total	< 0.0500	MAC = 5	0.0500	mg/L	2026-01-19	
Cadmium, total	0.000057	MAC = 0.007	0.000010	mg/L	2026-01-19	
Calcium, total	33.0	None Required	0.20	mg/L	2026-01-19	
Chromium, total	< 0.00050	MAC = 0.05	0.00050	mg/L	2026-01-19	
Cobalt, total	< 0.00010	N/A	0.00010	mg/L	2026-01-19	
Copper, total	0.00163	MAC = 2	0.00040	mg/L	2026-01-19	
Iron, total	0.011	AO ≤ 0.1	0.010	mg/L	2026-01-19	
Lead, total	< 0.00020	MAC = 0.005	0.00020	mg/L	2026-01-19	
Magnesium, total	3.58	None Required	0.010	mg/L	2026-01-19	
Manganese, total	0.00034	MAC = 0.12	0.00020	mg/L	2026-01-19	
Mercury, total	< 0.000040	MAC = 0.001	0.000040	mg/L	2026-01-19	HG1
Molybdenum, total	0.00126	N/A	0.00010	mg/L	2026-01-19	
Nickel, total	< 0.00040	N/A	0.00040	mg/L	2026-01-19	
Potassium, total	1.58	N/A	0.10	mg/L	2026-01-19	
Selenium, total	0.00179	MAC = 0.05	0.00050	mg/L	2026-01-19	



TEST RESULTS

REPORTED TO Interior Health Authority - Penticton
PROJECT Comprehensive 2026 for Ivor Norlin

WORK ORDER 26A1465
REPORTED 2026-01-21 14:16

Analyte	Result	Guideline	RL	Units	Analyzed	Qualifier
0210717; (26A1465-01) Matrix: Water Sampled: 2026-01-14, Continued						
Total Metals, Continued						
Sodium, total	1.67	AO ≤ 200	0.10	mg/L	2026-01-19	
Strontium, total	0.187	MAC = 7	0.0010	mg/L	2026-01-19	
Uranium, total	0.00204	MAC = 0.02	0.000020	mg/L	2026-01-19	
Zinc, total	< 0.0040	AO ≤ 5	0.0040	mg/L	2026-01-19	

Sample Qualifiers:

CT6 Results were based on lab temperature & lab pH.
 HG1 Sample bottle and preservation submitted is not suitable for Mercury analysis and analyte stability may be affected.
 HT2 The 15 minute recommended holding time (from sampling to analysis) has been exceeded - field analysis is recommended.



APPENDIX 1: SUPPORTING INFORMATION

REPORTED TO Interior Health Authority - Penticton
PROJECT Comprehensive 2026 for Ivor Norlin

WORK ORDER 26A1465
REPORTED 2026-01-21 14:16

Analysis Description	Method Ref.	Technique	Accredited	Location
Alkalinity in Water	SM 2320 B* (2021)	Titration with H ₂ SO ₄	✓	Kelowna
Anions in Water	SM 4110 B (2020)	Ion Chromatography	✓	Kelowna
Colour, True in Water	SM 2120 C (2021)	Spectrophotometry (456 nm)	✓	Kelowna
Conductivity in Water	SM 2510 B (2021)	Conductivity Meter	✓	Kelowna
Cyanide, SAD in Water	ASTM D7511-12	Flow Injection with In-Line UV Digestion and Amperometry	✓	Kelowna
Hardness in Water	SM 2340 B* (2021)	Calculation: 2.497 [total Ca] + 4.118 [total Mg] (Est)	✓	N/A
Langelier Index in Water	SM 2330 B (2021)	Calculation		N/A
pH in Water	SM 4500-H+ B (2021)	Electrometry	✓	Kelowna
Solids, Total Dissolved in Water	SM 1030 E (2021)	SM 1030 E		N/A
Total Metals in Water	EPA 200.2 / EPA 6020B	HNO ₃ +HCl Hot Block Digestion / Inductively Coupled Plasma-Mass Spectroscopy (ICP-MS)	✓	Richmond
Turbidity in Water	SM 2130 B (2020)	Nephelometry	✓	Kelowna

Note: An asterisk in the Method Reference indicates that the method has been modified from the reference method

Glossary of Terms:

RL	Reporting Limit (default)
<	Less than the specified Reporting Limit (RL) - the actual RL may be higher than the default RL due to various factors
°C	Degrees Celcius
AO	Aesthetic Objective
CU	Colour Units (referenced against a platinum cobalt standard)
MAC	Maximum Acceptable Concentration (health based)
mg/L	Milligrams per litre
NTU	Nephelometric Turbidity Units
OG	Operational Guideline (treated water)
pH units	pH < 7 = acidic, pH > 7 = basic
µS/cm	Microsiemens per centimetre
ASTM	ASTM International Test Methods
EPA	United States Environmental Protection Agency Test Methods
SM	Standard Methods for the Examination of Water and Wastewater, American Public Health Association



APPENDIX 1: SUPPORTING INFORMATION

REPORTED TO Interior Health Authority - Penticton
PROJECT Comprehensive 2026 for Ivor Norlin

WORK ORDER 26A1465
REPORTED 2026-01-21 14:16

General Comments:

The results in this report apply to samples received by CARO and analyzed in accordance with the Chain of Custody document. This analytical report must be reproduced in its entirety and must not be modified. CARO is not responsible for losses or damages resulting directly or indirectly from errors or omissions in the conduct of the testing. Any liability is limited to the cost of analysis. CARO will dispose of all samples within 30 days of sample receipt, unless otherwise agreed. The quality control (QC) data is available upon request.

Results in **Bold** indicate values that are above CARO's method reporting limits. Results in **red** indicate values above the regulatory limits where these have been included. Any Bold and/or highlighted results do not take into account method uncertainty. If you would like method uncertainty or regulatory limits to be included on your report, please contact your Account Manager: bwhitehead@caro.ca

Regulatory limits are added to test reports on request and are as a convenience only. While CARO makes every effort to ensure accuracy of regulatory limits, CARO assumes no liability for the use of this information. It remains the client's responsibility to ensure that regulatory limits are correct for their circumstances.